



Gray checked box is positive grounded. The battery bank for this MUST FLOAT

Yellow checked box can be traditionally grounded.

These can be Single pole breakers, but I would prefer dual pole breakers.

1 Amp Breaker

			Outback Power Systems, Inc	
DRAWN	NAME	DATE	19009 62nd Ave. NE Arlington, WA 98223 www.outbackpower.com	
CHECKED	NAME	DATE	TITLE:	
ENG APPR.	NAME	DATE	96 Volt Battery bank with FM or MX Controllers.	
MFG APPR.	NAME	DATE		
Q.A.	NAME	DATE		
REV. A			SIZE	DWG. NO.
			Scale: None	
			SHEET 1 OF 1	