



FOR USE WITH ONE OR TWO STRINGS INTO ONE OUTBACK FM100-AFCI CHARGE CONTROL, AND WHERE THE COMBINER CAN BE PLACED WHERE IT IS NEEDED FOR RSD

NOTES:
 1. THIS DRAWING IS SUGGESTED WIRING ONLY. IT IS THE RESPONSIBILITY OF THE INSTALLER TO MAKE SURE THIS SYSTEM IS INSTALLED ACCORDING TO APPLICABLE CODES. THIS EQUIPMENT SHOULD NOT BE ACCESSIBLE TO UNAUTHORIZED PERSONS.
 2. ALL METAL PARTS OF THIS SYSTEM SHOULD BE GROUNDED.

Drawing by:	Brad Bassett
Creation date:	2019-12-04
Revision by:	Brad Bassett
Revision date:	
Scale:	Not to scale

MODULE LEVEL RSD, FRS WITH COMBINER SHUTOFF

Drawing #	MLRSD-04A
Rev.	4.0